© YORK MANUFACTURING INC.

Reference: FLVC-TWF-OC-wDE

1: APPLY TWO CONTINUOUS ROWS OF US-100 SEALANT ALONG THE EDGE, AND INSTALL STAINLESS STEEL DRIP EDGE ON TOP OF SEALANT. PLACE US-100 SEALANT NEAR CORNER TO RECEIVE PREFORMED OUTSIDE CORNER.



2: PLACE CANT BEAD OF US-100 SEALANT. PLACE PREFORMED OUTSIDE CORNER ON TOP OF US-100 SEALANT BED AND CANT BEAD.



3: SEAL PREFORMED CORNER WITH US-100 SEALANT. APPLY 4" MINIMUM YORK 304 SA SPLICE TAPE O.C. AT LOCATION OF BUTT JOINT.





4: APPLY 4 ROWS OF SEALANT ON YORK 304 SA SPLICE TAPE. APPLY 2 ROWS OF SEALANT ON HORIZONTAL PLANE AND 1 ROW AT LOCATION OF TERM BAR TO RECEIVE FLASHING AND TERM BAR. LAY FLASH-VENT COPPER IN PLACE.



5: APPLY 2 ROWS OF SEALANT ON HORIZONTAL PLANE AND AT LOCATION OF TERM BAR TO RECEIVE FLASHING AND TERM BAR. REMOVE HORIZONTAL PORTION OF FLASHING TO PROPERLY BUTT THE FLASH-VENT SS TOGETHER. LAY FLASH-VENT COPPER IN PLACE.



6: INSTALL TERM. BAR AND MECHANICALLY FASTEN WITH APPROVED FASTENERS w/ NEOPRENE WASHER @ 8" O.C., AND WITHIN 1" OF EACH END OF BAR. APPLY CONTINUOUS BEAD OF US-100 SEALANT ON TOP OF TERMINATION BAR AND TOOL FOR PROPER ADHESION.

NOTE: FLASH-VENT MUST NOT OVERLAP AT LAPS. JOINING OF DRAINAGE MEMBRANE REQUIRES A 4" MINIMIM SPLICE TAPE AT ALL BUTT JOINTS OF FLASH-VENT. REFERENCE FLASH-VENT LAP DETAILS FOR JOINING OF MATERIALS.

OUTSIDE CORNER WITH DRIP EDGE DETAIL FLASH-VENT COPPER

NOTE: DESIGN TEAM IS RESPONSIBLE FOR DESIGN APPLICATION OF YORK FLASHINGS PRODUCTS AND ACCESSORIES. ALL PRODUCTS SHOULD BE USED IN COMPLIANCE WITH LOCAL BUILDING CODES AND INTERNATIONAL CODES OR STANDARDS. YORK PROVIDES THIS DETAIL AS GUIDANCE ONLY AND ACCEPTS NO LIABILITY FOR THE USE OR DUPLICATION OF THIS DETAIL. THE DESIGN TEAM IS RESPONSIBLE FOR THE DESIGN AND, AT THEIR DISCRETION,SHOULD DETERMINE IF THE RECOMMENDED PRODUCT APPLICATION IS SUITED FOR THE PROJECT AND PERFORMANCE DESIRED. THIS DETAIL IS SUBJECT TO MODIFICATION AT THE MANUFACTURER'S DISCRETION WITHOUT NOTICE. FOR THE MOST RECENT VERSION, PLEASE VISIT WWW.YORKFLASHINGS.COM